

Regional Wastewater System Capacity for Growth, by Community

Community	Projected Growth in SAC Units 2000-2010	SAC units 2000-2007 (thru 9/07)	Remainder	Impacted by Excess I/I	Capacity Improvements Scheduled Completion	Remarks	Projected Growth in SAC Units 2000-2020	SAC units 2000-2007 (thru 9/07)	Remainder	Projected Growth in SAC Units 2000-2030	SAC units 2000-2007 (thru 9/07)	Remainder
Andover	3,424	2,153	1,271	No	N/A		6,154	2,153	4,001	7,174	2,153	5,021
Anoka	684	375	309	No	2020		1,324	375	949	1,874	375	1,499
Apple Valley	6,354	4,033	2,321	No	N/A		10,315	4,033	6,282	11,740	4,033	7,707
Arden Hills	985	386	599	Yes	2015		1,880	386	1,494	5,425	386	5,039
Bayport	430	172	258	Yes	N/A		615	172	443	847	172	675
Birchwood	3	0	3		N/A		13	0	13	13	0	13
Blaine	9,788	7,503	2,285	No	2015		14,468	7,503	6,965	16,441	7,503	8,938
Bloomington	2,073	1,425	648	Yes	N/A		3,953	1,425	2,528	5,318	1,425	3,893
Brooklyn Center	443	235	208	No	N/A		863	235	628	785	235	550
Brooklyn Park	4,328	4,820	-492	No	2015	CAB Diversion Tunnel	8,270	4,820	3,450	11,415	4,820	6,595
Burnsville	1,785	2,456	-671	No	N/A		3,786	2,456	1,330	5,613	2,456	3,157
Centerville	271	329	-58		2008	White Bear Relief Sewer	536	329	207	788	329	459
Champlin	1,203	1,627	-424	No	N/A		1,973	1,627	346	2,828	1,627	1,201
Chanhassen	3,570	2,600	970	Yes	2020		6,579	2,600	3,979	8,599	2,600	5,999
Chaska	4,188	3,461	727	Yes	N/A		6,603	3,461	3,142	8,178	3,461	4,717
Circle Pines	358	363	-5	No	N/A		416	363	53	518	363	155
Columbia Hgts.	577	251	326	Yes	N/A		1,185	251	934	1,297	251	1,046
Coon Rapids	3,143	2,924	219	No	N/A		4,173	2,924	1,249	4,763	2,924	1,839
Corcoran	1,925	0	1,925	No	2008/2012	Southeast/Northeast	4,755	0	4,755	5,805	0	5,805
Cottage Grove	2,771	2,127	644	No	N/A		7,246	2,127	5,119	11,121	2,127	8,994
Crystal	359	47	312	No	N/A		792	47	745	1,232	47	1,185
Dayton (pt.)	621	45	576	No	2008		6,714	45	6,669	10,269	45	10,224
Deephaven	76	49	27	No	N/A		131	49	82	136	49	87
Eagan	3,295	3,590	-296	Yes	N/A		4,980	3,590	1,390	6,090	3,590	2,500
Eden Prairie	4,380	5,184	-804	Yes	N/A		6,030	5,184	846	7,180	5,184	1,996
Edina	809	1,656	-847	Yes	2012	Gateway Area	1,354	1,656	-302	1,974	1,656	318
Empire Twp.	333	287	46	No	N/A		1,035	287	748	1,737	287	1,450
Excelsior	59	87	-28	Yes	N/A		152	87	65	232	87	145
Falcon Hgts.	233	90	143	No	N/A		290	90	200	398	90	308

1. A "SAC unit" represents the wastewater flow from the equivalent of one residential unit, about 274 gallons per day. Commercial and industrial users could have multiple SAC units.
2. Capacity is available to serve 2010 projections, provided that communities comply with MCES standard peak-flow factors (i.e., non-excessive inflow/infiltration).
3. "Projected Growth" numbers reflect updated System Statement growth numbers as of November 28, 2007.
4. Completion is expressed as last day of year listed.
5. N/A = Not Applicable, because capacity is available to serve 2030 projections, provided that communities have non-excessive inflow/infiltration.
6. LS = Lift Station.
7. FM = Forcemain.

Regional Wastewater System Capacity for Growth, by Community

Community	Projected Growth in SAC Units 2000-2010	SAC units 2000-2007 (thru 9/07)	Remainder	Impacted by Excess I/I	Capacity Improvements Scheduled Completion	Remarks	Projected Growth in SAC Units 2000-2020	SAC units 2000-2007 (thru 9/07)	Remainder	Projected Growth in SAC Units 2000-2030	SAC units 2000-2007 (thru 9/07)	Remainder
Farmington	3,462	3,368	94	No	N/A		6,552	3,368	3,184	8,627	3,368	5,259
Forest Lake	3,201	2,030	1,171	No	2008	White Bear Relief Sewer	5,797	2,030	3,767	8,455	2,030	6,425
Fridley	469	709	-240	Yes	N/A		909	709	200	1,424	709	715
Gem Lake	30	0	30	No	N/A		132	0	132	184	0	184
Golden Valley	626	928	-302	Yes	2012		899	928	-29	1,369	928	441
Greenfield	145	0	145	Yes	N/A		315	0	315	465	0	465
Greenwood	38	29	9	Yes	N/A		48	29	19	49	29	20
Hastings	2,138	2,469	-331	No	2015	New, larger plant	4,351	2,469	1,882	5,873	2,469	3,404
Hilltop	15	0	15	No	N/A		18	0	18	21	0	21
Hopkins	383	342	41	Yes	2013	Primarily LS/FM Replacement	743	342	401	1,000	342	658
Hugo	4,962	2,808	2,154	No	2008	White Bear Relief Sewer	9,012	2,808	6,204	13,557	2,808	10,749
Independence	0	15	-15	Yes	N/A		28	15	13	68	15	53
Inver Grove Hgts.	3,367	2,640	727	No	N/A		5,907	2,640	3,267	6,467	2,640	3,827
Lake Elmo	565	231	334	No	2008	East and West	3,348	231	3,117	5,900	231	5,669
Laketown Twp.	0	13	-13	Yes	N/A	Victoria/Waconia Svc. Area	-2	13	-15	-222	13	-235
Lakeville	6,695	6,598	97	Yes	N/A		15,060	6,598	8,462	20,620	6,598	14,022
Landfall	9	0	9	No	N/A		9	0	9	10	0	10
Lauderdale	29	23	6	Yes	N/A		120	23	97	122	23	99
Lexington	103	29	74	No	N/A		152	29	123	205	29	176
Lilydale	248	103	145	Yes	N/A		249	103	146	252	103	149
Lino Lakes	2,557	1,972	585	No	2015	West	5,674	1,972	3,702	7,187	1,972	5,215
Little Canada	604	284	320	No	N/A		1,027	284	743	1,447	284	1,163
Long Lake	149	111	38	Yes	N/A		254	111	143	354	111	243
Mahtomedi	524	368	156	No	2011		698	368	330	805	368	437
Maple Grove	8,077	7,961	116	No	2015	CAB Diversion Tunnel/LS	14,229	7,961	6,268	18,235	7,961	10,274
Maple Plain	180	200	-20	Yes	N/A		230	200	30	305	200	105
Maplewood	2,209	2,333	-124	Yes	N/A		3,479	2,333	1,146	5,154	2,333	2,821
Medicine Lake	24	2	22	Yes	N/A		34	2	32	44	2	42

1. A "SAC unit" represents the wastewater flow from the equivalent of one residential unit, about 274 gallons per day. Commercial and industrial users could have multiple SAC units.
2. Capacity is available to serve 2010 projections, provided that communities comply with MCES standard peak-flow factors (i.e., non-excessive inflow/infiltration).
3. "Projected Growth" numbers reflect updated System Statement growth numbers as of November 28, 2007.
4. Completion is expressed as last day of year listed.
5. N/A = Not Applicable, because capacity is available to serve 2030 projections, provided that communities have non-excessive inflow/infiltration.
6. LS = Lift Station.
7. FM = Forcemain.

Regional Wastewater System Capacity for Growth, by Community

Community	Projected Growth in SAC Units 2000-2010	SAC units 2000-2007 (thru 9/07)	Remainder	Impacted by Excess I/I	Capacity Improvements Scheduled Completion	Remarks	Projected Growth in SAC Units 2000-2020	SAC units 2000-2007 (thru 9/07)	Remainder	Projected Growth in SAC Units 2000-2030	SAC units 2000-2007 (thru 9/07)	Remainder
Medina	603	551	52	Yes	N/A		1,785	551	1,234	2,855	551	2,304
Mendota	3	8	-5	Yes	N/A		14	8	6	35	8	27
Mendota Hgts.	524	834	-310	No	N/A		759	834	-75	984	834	150
Mpls./Fort Snelling	11,912	10,609	1,303	Yes	N/A		21,727	10,609	11,118	28,462	10,609	17,853
Minnetonka	1,159	1,450	-291	Yes	N/A		2,080	1,450	630	3,099	1,450	1,649
Minnetonka Beach	21	3	18	Yes	N/A		23	3	20	23	3	20
Minnetrista	1,354	677	677	No	2020		1,971	677	1,294	3,480	677	2,803
Mound	370	212	158	Yes	2010		628	212	416	836	212	624
Mounds View	494	700	-207	No	2020		819	700	119	1,244	700	544
New Brighton	479	580	-101	Yes	N/A		957	580	377	1,217	580	637
New Hope	649	527	122	Yes	N/A		1,182	527	655	1,612	527	1,085
Newport	303	50	253	No	N/A		644	50	594	990	50	940
North Oaks	168	364	-196	No	N/A		317	364	-47	466	364	102
North St. Paul	500	100	400	No	N/A		897	100	797	1,547	100	1,447
Oak Park Hgts.	706	833	-127	No	N/A		861	833	28	1,091	833	258
Oakdale	1,129	1,830	-701	Yes	N/A		1,896	1,830	66	2,961	1,830	1,131
Orono	396	379	17	Yes	N/A		1,100	379	721	1,174	379	795
Osseo	74	125	-51	Yes	N/A		197	125	72	402	125	277
Plymouth	4,771	5,302	-531	Yes	N/A		7,446	5,302	2,144	9,301	5,302	3,999
Prior Lake	4,340	3,433	907	No	2020		7,415	3,433	3,982	10,490	3,433	7,057
Ramsey	5,719	2,726	2,993	No	2020	Phased Expansion	12,426	2,726	9,700	13,873	2,726	11,147
Richfield	1,894	812	1,082	No	N/A		3,819	812	3,007	5,744	812	4,932
Robbinsdale	468	51	417	No	N/A		1,003	51	952	1,043	51	992
Rosemount	5,540	3,014	2,526	No	2008	Interceptor to Empire Plant	9,125	3,014	6,111	9,230	3,014	6,216
Roseville	1,064	1,040	24	Yes	N/A		1,676	1,040	636	2,246	1,040	1,206
Savage	4,222	3,247	975	Yes	N/A		8,064	3,247	4,817	9,657	3,247	6,410
Shakopee	7,653	6,696	957	No	N/A		12,328	6,696	5,632	14,403	6,696	7,707
Shoreview	1,048	726	322	Yes	N/A		1,468	726	742	1,518	726	792

1. A "SAC unit" represents the wastewater flow from the equivalent of one residential unit, about 274 gallons per day. Commercial and industrial users could have multiple SAC units.
2. Capacity is available to serve 2010 projections, provided that communities comply with MCES standard peak-flow factors (i.e., non-excessive inflow/infiltration).
3. "Projected Growth" numbers reflect updated System Statement growth numbers as of November 28, 2007.
4. Completion is expressed as last day of year listed.
5. N/A = Not Applicable, because capacity is available to serve 2030 projections, provided that communities have non-excessive inflow/infiltration.
6. LS = Lift Station.
7. FM = Forcemain.

Regional Wastewater System Capacity for Growth, by Community

Community	Projected Growth in SAC Units 2000-2010	SAC units 2000-2007 (thru 9/07)	Remainder	Impacted by Excess I/I	Capacity Improvements Scheduled Completion	Remarks	Projected Growth in SAC Units 2000-2020	SAC units 2000-2007 (thru 9/07)	Remainder	Projected Growth in SAC Units 2000-2030	SAC units 2000-2007 (thru 9/07)	Remainder
Shorewood	231	243	-12	No	N/A		360	243	117	451	243	208
South St. Paul	195	728	-533	Yes	N/A		507	728	-221	917	728	189
Spring Lake Park	26	174	-148	No	N/A		86	174	-88	288	174	114
Spring Park	85	163	-78	No	N/A		183	163	20	239	163	76
St. Anthony	351	422	-71	Yes	N/A		684	422	262	1,006	422	584
St. Bonifacius	423	259	164	Yes	2020		427	259	168	532	259	273
St. Louis Park	1,502	2,380	-878	No	2012	North East area	2,717	2,380	337	3,817	2,380	1,437
St. Paul	8,315	7,789	526	Yes	N/A		15,985	7,789	8,196	22,515	7,789	14,726
St. Paul Park	1,141	260	881	No	N/A		2,024	260	1,764	2,406	260	2,146
Stillwater	1,770	1,872	-102	Yes	N/A		2,363	1,872	491	2,918	1,872	1,046
Tonka Bay	127	19	108	Yes	N/A		145	19	126	167	19	148
Vadnais Hgts.	575	588	-13	Yes	N/A		1,103	588	515	2,433	588	1,845
Victoria	2,686	1,146	1,540	No	2010	Victoria Area System	5,966	1,146	4,820	9,041	1,146	7,895
Waconia	2,086	1,608	478	Yes	2013	Victoria Area System	5,731	1,608	4,123	7,886	1,608	6,278
Wayzata	168	84	84	No	2015		278	84	194	285	84	201
West St. Paul	345	560	-215	Yes	2009	Riverview Siphon	810	560	250	1,160	560	600
White Bear Lake	1,032	968	64	No	N/A		1,319	968	351	1,464	968	496
White Bear Twp.	1,741	595	1,146	No	2008	White Bear Relief Sewer	2,058	595	1,463	2,400	595	1,805
Willernie	25	3	22	No	N/A		35	3	32	36	3	33
Woodbury	6,833	6,768	65	No	N/A		14,739	6,768	7,971	19,379	6,768	12,611
Woodland	7	0	7	No	N/A		9	0	9	14	0	14

1. A "SAC unit" represents the wastewater flow from the equivalent of one residential unit, about 274 gallons per day. Commercial and industrial users could have multiple SAC units.
2. Capacity is available to serve 2010 projections, provided that communities comply with MCES standard peak-flow factors (i.e., non-excessive inflow/infiltration).
3. "Projected Growth" numbers reflect updated System Statement growth numbers as of November 28, 2007.
4. Completion is expressed as last day of year listed.
5. N/A = Not Applicable, because capacity is available to serve 2030 projections, provided that communities have non-excessive inflow/infiltration.
6. LS = Lift Station.
7. FM = Forcemain.