



Business Item: 2025-010


Adoption of Facility Plan for the Forest Lake Interceptor
7029 Rehabilitation, Project Number 808603



Environment Committee: January 14, 2025

Chris Remus

Project Location Map



Improvements Required



Condition assessment of this interceptor determined the need for a project based on the overall poor condition of the existing 36" reinforced concrete pipe (RCP) originally constructed in 1971.

A condition assessment was performed on this pipe in 2018 and found to be in poor condition (rating 4).

Three areas of improvements are proposed for the project which include cleaning the existing interceptor, rehabilitation through trenchless methods, and replacement or rehabilitation of the existing structures.

Next Steps

Summary of the facility plan public hearing process

- September 25, 2024: Authorized granted from Metropolitan Council to hold public hearing
- November 18, 2024: Public Hearing held at City of Forest Lake
- January 14, 2025: Environment Committee considers comments and recommends approval to adopt by Metropolitan Council
- January 22, 2025: Metropolitan Council considers comments and adopts final Facility Plan
- Prior to March 7, 2025: If adopted, final facility plan is submitted to Public Facilities Authority and MPCA for inclusion in the Intended Use Plan

Summary of Public Comments

One comment received from a local resident near project site

Subject: Concern of construction noise and work after hours

Resolution: Noted that construction will take place during the hours as stated in city of Hugo and Forest Lake ordinances

Proposed Action



That the Metropolitan Council adopt the Facility Plan for the Forest Lake Interceptor 7029 Rehabilitation, Project Number 808603, per the attached Resolution Number 2025-2.



Questions

Chris Remus

Assistant Manager,
Interceptor Engineering,
Interceptor Services

christopher.remus@metc.state.mn.us

(651) 602-4538

