

Plant Inflow Summary Report 12 Month Moving Averages

April 2019

DMR Current Location	City	Design Flow mgd	DMR Component	DMR Reported Result (Actual)	DMR Units
BLUE_LAKE	Shakopee	42	Flow	27.17	mgd
			CBOD-5day	270	mg/L
EAGLES_POINT	Cottage Grove		Flow	4.86	mgd
			CBOD-5day	228	mg/L
EAST_BETH	East Bethel	0.41	Flow	0.050	mgd
			CBOD-5day	164	mg/L
EMPIRE	Farmington	28.61	Flow	11.04	mgd
			CBOD-5day	292	mg/L
HASTINGS	Hastings	2.69	Flow	1.51	mgd
			CBOD-5day	259	mg/L
METRO	St. Paul	314	Flow	176.38	mgd
			CBOD-5day	342	mg/L
SENECA	Eagan	38	Flow	21.55	mgd
			CBOD-5day	216	mg/L
ST_CROIX_VALLEY	Oak Park Heights	5.8	Flow	3.20	mgd
			CBOD-5day	162	mg/L

Use the following resources to help you determine which plant is affected:

(1) Sewershed map for treatment plants: <http://giswebsite.metc.state.mn.us/mapgallery/pdfs/LongTermCurrentLg.pdf>

(2) Listing of communities served by each treatment plant:

[http://metro council.org/Wastewater-Water/Services/Wastewater-Treatment-\(1\)/Communities-Served-by-7-MCES-Treatment-Plant](http://metro council.org/Wastewater-Water/Services/Wastewater-Treatment-(1)/Communities-Served-by-7-MCES-Treatment-Plant)

Note: Calculation of average values is based on data submitted to the MPCA on Discharge Monitoring Reports (DMRs) for the time period indicated on top.