Plant Inflow Summary Report 12 Month Moving Averages

September 2025

DMR Current Location	City	Design Flow (mgd)	DMR Component	DMR Reported Result (Actual)	DMR Units
BLUE_LAKE	Shakopee	42.000	Flow	26.46	mgd
			CBOD-5day	215	mg/L
EAGLES_POINT	Cottage Grove	11.9	Flow	5.93	mgd
			CBOD-5day	254	mg/L
EAST_BETH	East Bethel	0.41	Flow	0.077	mgd
			CBOD-5day	208	mg/L
EMPIRE	Farmington	28.61	Flow	11.66	mgd
			CBOD-5day	250	mg/L
HASTINGS	Hastings	2.96	Flow	1.48	mgd
			CBOD-5day	179	mg/L
METRO	St. Paul	314.000	Flow	174.39	mgd
			CBOD-5day	213	mg/L
ROGERS	Rogers	1.602	Flow	1.130	mgd
			CBOD-5day	211	mg/L
SENECA	Eagan	38	Flow	20.72	mgd
			CBOD-5day	222	mg/L
ST_CROIX_VALLEY	Oak Park Heights	5.8	Flow	2.60	mgd
			CBOD-5day	157	mg/L

Use the following resources to help you determine which plant is affected:

http://metrocouncil.org/Wastewater-Water/Services/Wastewater-Treatment-(1)/Communities-Served-by-7-MCES-Treatment-Plant

⁽¹⁾ Sewershed map for treatment plants: http://giswebsite.metc.state.mn.us/mapgallery/pdfs/LongTermCurrentLg.pdf

⁽²⁾ Listing of communities served by each treatment plant: